



27 February 2020

Re: Parliament Inquiry Newcastle 20 February 2020

I appeared before the inquiry on behalf of Central Coast Council and some questions were taken on notice. Below are the responses.

1. How many buildings in the Central Coast LGA contain aluminium composite cladding?

Response

- 29 buildings owners voluntarily listed on the register within the Central Coast Council Local Government Area.

2. What Hospital contains the cladding?

Response

- Gosford Public Hospital. 4 separate buildings on the site with a low risk. The hospital was renovated, so combustible cladding is present in sections of the new building as well older parts which have been reclad.

3. How many are high risk and how many are the Crown?

Response

- 19 buildings have been assessed as no or low risk and require no further action.
- 10 buildings are low to medium risk, with further investigations currently under way.
- 4 of the 10 buildings are public, NSW government owned buildings. (Crown)
- Council's Fire Safety officer is liaising with building owners for the remaining 6 buildings, and monitoring progress to remove the risk.
-

Scott Rathgen

Section Manager

BUILDING CERTIFICATION NORTH



Wyong Office: 2 Hely St / PO Box 20 Wyong NSW 2259 | P 02 4350 5555

Gosford Office: 49 Mann St / PO Box 21 Gosford NSW 2250 | P 02 4325 8222

E ask@centralcoast.nsw.gov.au | W www.centralcoast.nsw.gov.au | ABN 73 149 644 003